



**NO SCALE**

**NOTES:**

1. JOINTS FOR GRAVITY SANITARY SEWER SHALL USE PUSH ON BELL AND SPIGOT TYPE WITH RUBBER RING GASKETS CONFORMING TO ASTM D3212 AND ASTM F477 FOR SDR 26 APPLICATIONS.
2. WHERE INDICATED ON THE PLANS, SANITARY SEWER PRESSURE PIPE SHALL COMPLY WITH ASTM D2241 FOR 160 PSI PRESSURE RATED PIPE SDR 26, MADE OF TYPE 1, GRADE 1 POLYVINYL CHLORIDE CONFORMING TO ASTM D1784. JOINTS SHALL USE PUSH-ON BELL AND SPIGOT TYPE WITH RUBBER RING SEAL GASKETS CONFORMING TO ASTM D3139.
3. GRAVITY SANITARY SEWER FITTINGS SHALL COMPLY WITH ASTM D3212 WITH A SDR OF 26. THE FITTINGS SHALL BE MADE WITH MANUFACTURER'S STANDARD PIPE BELLS AND GASKETS. GRAVITY SEWER RISERS AND SERVICE PIPE AND FITTINGS SHALL COMPLY WITH ASTM D3034 WITH A SDR OF 26.
4. PRESSURE SANITARY SEWER FITTINGS SHALL BE FACTORY FABRICATED WITH ATTACHED MAIN LINE COUPLING, WITH SAME RATING AS PIPE. PRESSURE SEWER RISERS AND SERVICE PIPE AND FITTINGS SHALL COMPLY WITH ASTM D2241, 160 PSI PRESSURE RATED, SDR 26 PIPE. SEPARATE NOTIFICATION SHALL BE PROVIDED TO PUBLIC WORKS DEPARTMENT PRIOR TO INSTALLING PRESSURE SANITARY SEWERS.
5. ALL SANITARY SEWERS SHALL BE PRESSURE TESTED IN ACCORDANCE WITH ARTICLE 31-1.11B(3) OF THE STANDARD SPECIFICATIONS FOR SEWER & WATER CONSTRUCTION IN ILLINOIS, FIFTH EDITION; AND DEFLECTION TESTED IN ACCORDANCE WITH ARTICLE 31-1.11B(4) OF THE STANDARD SPECIFICATIONS FOR SEWER & WATER CONSTRUCTION IN ILLINOIS, FIFTH EDITION. DEFLECTION TESTING SHALL BE DONE NO SOONER THAN 30 DAYS AFTER THE PIPE HAS BEEN BACKFILLED. NO SOONER THAN 30 DAYS AFTER SEWERS HAVE BEEN INSTALLED, THEY SHALL BE INSPECTED BY CLOSED CIRCUIT COLOR TELEVISION TO DETERMINE IF ANY PIPE INSTALLATION DEFECTS HAVE OCCURRED, AND TO DETERMINE THE LOCATION OF SERVICES. ONE COPY OF THE VIDEOTAPE AND WRITTEN INSPECTION REPORT SHALL BE FURNISHED TO THE VILLAGE.
6. SEWER PLUGS SHALL BE INSTALLED AT DOWNSTREAM ENDS OF ALL NEW SEWERS AND LEFT IN PLACE UNTIL VILLAGE ACCEPTS SEWERS. SEWER PLUGS SHALL BE INSTALLED AT UPSTREAM ENDS OF NEW SEWERS AT THE END OF EACH DAY'S WORK.

\* THE VILLAGE RESERVES THE RIGHT TO REQUIRE ALTERNATE SANITARY SEWER PIPE AND JOINT MATERIALS AS IT DEEMS NECESSARY

**VILLAGE OF NEW LENOX  
STANDARD DETAIL  
FOR  
SANITARY SEWER  
INSTALLATION**

REV:	5
DATE:	JANUARY 2018
FILE:	SANITARY/SSI