



NOTES:

1. ALL CURBS AND SIDEWALKS SHALL BE CONSTRUCTED WITH IDOT CLASS "SI" CONCRETE WITH A MINIMUM COMPRESSIVE STRENGTH OF 3,500 PSI AT 14 DAYS.
2. PARKWAYS SHALL BE FINISHED WITH A MINIMUM OF SIX INCHES OF TOPSOIL.
3. TESTING OF SUBGRADE AND ALL ROADWAY MATERIALS SHALL BE DONE IN ACCORDANCE WITH THE VILLAGE'S SUBDIVISION ORDINANCE.

VILLAGE OF NEW LENOX  
 STANDARD DETAIL  
 FOR ROADWAY  
 CROSS-SECTION  
 RESIDENTIAL

REV:	9
DATE:	JANUARY 2018
FILE:	TRANS\RD\SEC1