



NOTES:

1. A CONCRETE PAVEMENT SECTION ALTERNATIVE MAY BE SUBMITTED FOR REVIEW AND APPROVAL
2. ALL CURBS AND SIDEWALKS SHALL BE CONSTRUCTED WITH A MINIMUM COMPRESSIVE STRENGTH OF 3500 PSI AT 14 DAYS.
2. PARKWAYS SHALL BE FINISHED WITH A MINIMUM OF SIX INCHES OF TOPSOIL.
3. TESTING OF SUBGRADE AND ALL ROADWAY MATERIALS SHALL BE DONE IN ACCORDANCE WITH THE VILLAGE'S SUBDIVISION ORDINANCE.

VILLAGE OF NEW LENOX
STANDARD DETAIL
FOR
INDUSTRIAL

REV:	3
DATE:	JANUARY 2018
FILE:	TRANS\RD\XSEC6