



**SECTION**

CORPORATION STOP CATALOG NUMBERS			
SIZE	FORD	AY McDONALD	MUELLER
1"	F1000-4-Q-NL	74701Q-1	B25008-1
1-1/2"	FB1000-6-Q-NL	74701BQ-1-1/2	B25008-1-1/2
2"	FB1000-7-Q-NL	74701BQ-2	B25008-2

CURB STOP CATALOG NUMBERS			
SIZE	FORD	AY McDONALD	MUELLER
1"	B44-444-Q-NL	76104Q-1	B-25155-1
1-1/2"	B44-666-Q-NL	76104Q-1-1/2	B-25155-1-1/2
2"	B44-777-Q-NL	76104Q-2	B-25155-2

**NO SCALE**

- NOTE:
1. TRENCH BACKFILL SHALL BE INSTALLED PER WATER MAIN INSTALLATION DETAIL.
  2. WATER SERVICE LENGTHS: SEE SECTION 503.02 IN DESIGN STANDARD. SPLICES IN THE WATER SERVICE SHALL NOT BE PERMITTED.
  3. SERVICES GREATER THAN OR EQUAL TO 1-1/2-INCHES IN DIAMETER SHALL REQUIRE SADDLES/SAC NUTS. THE SADDLE SHALL BE AN EPOXY COATED DUCTILE IRON BODY WITH STAINLESS STEEL STRAPS, SMITH BLAIR #317 OR JCM #404.

VILLAGE OF NEW LENOX  
STANDARD DETAIL  
FOR  
WATER SERVICE

REV:	3
DATE:	MAY 2025
FILE:	WATER\WSRV