



NO SCALE

NOTE:

1. 20 FEET OF DUCTILE IRON PIPE WITH PROTECTO 401 COATING SHALL BE INSTALLED UPSTREAM OF TEE.
2. C-900 WATER QUALITY PIPE MAY BE USED IN LIEU OF OF PROTECTO 401 PIPE UPON APPROVAL OF THE SANITARY PUBLIC WORKS DEPARTMENT.
3. AN EPOXY COATING SHALL BE REQUIRED FOR INTERNAL DROP, EXTERNAL DROP, AND/OR FORCE MAIN EFFLUENT MANHOLES. THE COATING SHALL BE RAVEN 405 OR APPROVED EQUAL FOR COATING. THE THICKNESS OF THE COATING SHALL BE A MINIMUM OF 150 MIL'S. PLEASE CONTACT THE VILLAGE'S SANITARY PUBLIC WORKS DEPARTMENT FOR ANY QUESTIONS, INFORMATION, AND APPROVALS.

VILLAGE OF NEW LENOX  
STANDARD DETAIL  
FOR  
DROP CONNECTION

REV:	5
DATE:	November 12, 2024
FILE:	SANITARYDROP