



NO SCALE

NOTES:

1. ALL BOLTS BELOW GRADE ON FIRE HYDRANT SHALL BE STAINLESS STEEL.
 2. ALL BOLTS ON AUXILIARY VALVE SEAL PLATE AND BONNET SHALL BE STAINLESS STEEL.
 3. THRUST BLOCKING SHALL BE CONSTRUCTED SO HYDRANT DRAIN HOLE IS NOT OBSTRUCTED.
 4. HYDRANT SHALL BE PAINTED RED.
- EJIW PART #00982020
5. ALL MATERIAL MUST BE "MADE IN USA".

<p>VILLAGE OF NEW LENOX STANDARD DETAIL FOR FIRE HYDRANT</p>	
REV:	8
DATE:	MAY 2025
FILE:	WATER\FRHYDET